



Emergency Generator Application & Data Sheet

Status <input type="checkbox"/> New <input type="checkbox"/> Moved <input type="checkbox"/> Change <input type="checkbox"/> Removed		Typical Entry	
Generator Code **		EGD – 073	
FAMIS Code		117005	
Status		Active/Inactive/REMOVED	
Date Removed		1/10/07	
Location Bldg Name*		Gates Computer	
Location Bldg No.*		07-450	
Service Bldg Name*		Gilbert Biology	
Service Bldg No.*		07-4420	
Generator Manufacturer		ONAN	
Gen. Model No.		DFLB-4487839	
Gen. Serial No.		K000172325	
Gen. Specification No.		56Z9747	
Gen. R.P.M.		1800	
Gen. Power Factor		0.8	
Gen. Amps		1656	
Gen. kW*		1100	
Gen. kVA*		1375	
Gen. Voltage 1*		480/277	
Gen. Voltage 2		208/120	
Gen. Hz		60	
Gen. Phase		3 Phase	
Engine Manufacture		CUMMINS	
Engine Model		KTA50-G2	
Engine Serial No.		33147317	
Engine Fuel Type		Diesel/Nat. Gas/Propane/Gasoline	
Engine Fuel Tank Size		1150	
Engine Running Time		12 Hrs	
Data	Date	Name/Email	Date
Note			

(*Asterisk items are needed @ kick-off. Balance of items when generator is selected.)

(** Provided by Utilities upon receipt of initial data sheet)

Return to: Loanne Damme, Power Systems Administrator

Phone: 725-5499 Fax: 723-3191 Email: loanne@bonair.stanford.edu

Rev. DateAUG 26, 2009